

14-
APW 1219-10-002-024

✓
Jack White Custom Homes
423 Claire Court
Gardnerville, NV 89460

August 1, 2002

letter

Mr. Darin Whatcott
Building Official, Douglas County

Re: French Residence 285 Sierra Country Circle Gardnerville, NV 89460

Dear Mr. Whatcott:

At the request of my clients, there were some countertop changes in the laundry room area at the above referenced residence. An electrical sub-panel is not in conformance with the 1999 National Electrical Code (Section 110-26(a)).

While there is working space at the sub-panel, there is not 30 inches clear to the floor as required by Section 110-26(a)3. Under Section 90-4 enforcement, I am requesting that the location be approved under the following conditions.

1. The panel shall be permanently labeled – “CAUTION reduced working clearances, equipment to be accessed by qualified personnel only”.
2. Enclosed is a “hold harmless” letter releasing Douglas County from any liability from the Owners.

Thank you for your consideration on this matter.

Respectfully,

Jack R. White

Jack R. White
President

REQUESTED BY
Jack White
IN OFFICIAL RECORDS OF
DOUGLAS CO., NEVADA

2002 AUG -6 PM 12: 48

Enclosure

LINDA SLATER
RECORDER
\$14.00 PAID BC DEPUTY

0548818
BK0802PG01501