

Recorder's Office Cover Sheet

Recording Requested By:

Name: HEATHER MACDONNELL

Department: PUBLIC WORKS




00122581202009563520520525

KAREN ELLISON, RECORDER

Type of Document: (please select one)

- Agreement
- Contract
- Grant
- Change Order
- Easement
- Other

specify: _____



Date of Issuance: 10/30/2020	Effective Date: 10/30/2020
Owner: Douglas County	Owner's Contract No.: 15501
Contractor: Resource Development Company	Contractor's Project No.: 18017
Engineer: Keller Associates	Engineer's Project No.: 216030
Project: NVWWTP Improvements	Contract Name: NVWWTP Improvements

The Contract is modified as follows upon execution of this Change Order. WCD #32, and WCD #33 occurred before Milestone #1, and WCD #31 and WCD #34 occurred after. The adjustment in contract times reflects this. Description: See page 2 of this document for further descriptions. Attachments: Change order descriptions, WCD #31, WCD #32, WCD #33, WCD #34

CHANGE IN CONTRACT PRICE	CHANGE IN CONTRACT TIMES <i>[note changes in Milestones if applicable]</i>
Original Contract Price: \$ <u>9,155,284.00</u>	Original Contract Times: NTP: June 25, 2018 Substantial Completion: <u>480 Days (October 18, 2019)</u> Milestone #1: <u>365 Days (June 25, 2019)</u> Ready for Final Payment: <u>540 days (December 17, 2019)</u> days
[Increase] [Decrease] from previously approved Change Orders No. <u>1</u> to No. <u>11</u> : \$ <u>249,891.28</u>	[Increase] [Decrease] from previously approved Change Orders No. <u>1</u> to No. <u>11</u> : Substantial Completion: <u>156 days</u> Milestone #1: <u>156 days</u> Ready for Final Payment: <u>156 days</u>
Contract Price prior to this Change Order: \$ <u>9,405,175.28</u>	Contract Times prior to this Change Order: Substantial Completion: <u>636 Days (March 22, 2020)</u> Milestone #1: <u>521 Days (December 18, 2019)</u> Ready for Final Payment: <u>696 Days (May 21, 2020)</u>
[Increase] [Decrease] of this Change Order: \$ <u>60,762.30</u>	[Increase] [Decrease] of this Change Order: Substantial Completion: <u>15 Days</u> Milestone #1: <u>14 Days</u> Ready for Final Payment: <u>15 Days</u>
Contract Price incorporating this Change Order: \$ <u>9,465,937.58</u>	Contract Times with all approved Change Orders: Substantial Completion: <u>651 Days (April 6, 2020)</u> Milestone #1: <u>535 Days (January 1, 2020)</u> Ready for Final Payment: <u>711 Days (June 5, 2020)</u>

RECOMMENDED: By: <u>[Signature]</u> Title: <u>Project Engineer</u> Date: <u>10/30/2020</u>	ACCEPTED: By: <u>[Signature]</u> Title: <u>Director Public Works</u> Date: <u>11-04-2020</u>	ACCEPTED: By: <u>[Signature]</u> Title: <u>Contractor Authorized Signature</u> Date: <u>11/9/2020</u>
---	---	--

Owner (Authorized Signature)
By: [Signature]
Title: Douglas County Manager

FILED
NO. 2020-192

11-13-20
DATE

DOUGLAS COUNTY CLERK
MINDEN, NV

BY [Signature] DEPUTY

Change Order Descriptions

1. WCD #31 (PCO #59) – Influent Structure 12-inch SI Abandonment
 - a. This WCD includes the labor and materials to abandon the 12-inch SI pipe in the aerobic digester influent structure.
 - b. \$1,138.78
 - c. 0 Contract Days

2. WCD #32 (PCO #58)
 - a. This WCD accounts for an impact to the Contractor's schedule due to the COVID-19 pandemic.
 - b. No change in contract cost
 - c. 14 contract days

3. WCD #33 (PCO #35)
 - a. This WCD includes the removal/replacement/upsizing the transformer connecting to BCP-151, installation of additional breakers, conduits, conductors, potholing, and excavation in order to provide a complete and functioning heat trace system
 - b. \$56,204.99
 - c. 0 Contract Days

4. WCD #34 (PCO #61)
 - a. The old effluent pumps have been removed from the operations building. Subsequently, the discharge piping was abandoned. However, the abandoned discharge piping connects to a live pipeline in a nearby vault. Unfortunately, water is flowing back into the abandoned pipe. To prevent this, the abandoned pipe will be cut and capped outside of the vault described above.
 - b. \$3,418.53
 - c. 1 contract day



Work Change Directive

Owner:	Douglas County	WCD No.:	31
Project Name:	NVWWTP Improvements Project	Project No.:	216030
Contractor:	Resource Development Company	Issued By:	Jeremy Wilson
Attention:	Alex Nevarez	Date Issued:	09/17/2020

Reason for Change: The planned modifications to the existing biolac influent structure are shown on sheet 160-SM-2001. The existing abandoned 12-inch SI pipe shown in section A extends approximately 8-inches into the existing vault. To allow for properly abandoning this pipe, the end and associated grout will need to be removed flush with the vault.

Description of change(s): This WCD includes the labor and materials to properly abandon the 12-inch SI pipe.

Attachments: Contractor's proposed change order.

Contract Sum Adjustment: The proposed basis of adjustment to the Contract Sum or Guaranteed Maximum Price is (Place an X in the appropriate box).

- Lump Sum increase of \$1,138.78
- Unit Price of
- Cost of Work not to exceed
- Contractor Submit TM Ticket

Contract Time Adjustment: An increase in contract time is not anticipated as part of this WCD.

When signed by the Owner and Engineer authorized representatives and received by the Contractor, this document becomes effective immediately as a Construction Change Directive, and the Contractor shall proceed with the change(s) described above. The Contractor's signature, signed by an authorized representative, indicates agreement with the proposed adjustments in Contract Sum and Contract Time set forth in this Construction Change Directive.

Keller Associates, Inc.

Engineer

1325 Airmotive Way Suite 380

Reno, Nevada 89502

(Address)


By (Authorized Signature)

Jeremy Wilson

(Printed Name)

09/17/2020

Date


Douglas County

Owner

1120 Airport Road, Bldg F2

Minden, Nevada 89423

(Address)


By (Authorized Signature)

Philip Ritger

(Printed Name)

09-24-2020

Date


Resource Development Company

Contractor

1050 Linda Way

Sparks, Nevada 89431

(Address)


By (Authorized Signature)

CHRISTOPHER ERB

(Printed Name)

09/25/20

Date



RESOURCE DEVELOPMENT COMPANY

PCO #59 - INFLUENT STRUCTURE 12 INCH SI ABANDONMENT

Date: AUGUST 28, 2020

Project: NVWWTP Improvements

ATTN: Jeremy Wilson, PE – Keller Associates

Mr. Wilson,

This PCO is to document the process for RDC to remove the existing 12" pipe penetration in the existing Influent Structure in preparation of abandoning the 12" pipeline per plan sheet 1160-SM-2001. This work covers evacuation of the influent water, confined space entry, grinding and cutting and removal of the pipe end and grout.

PCO Extra Work Total: \$1,138.78

Additional Contract Days: 0 Contract Days

Please don't hesitate to contact me if you have any questions or need any clarification.

Sincerely,

Christopher Erb

Christopher Erb

Resource Development Company

Cc: Ron Roman, PE – DCPW

 Scott McCullough - DCPW



RESOURCE DEVELOPMENT COMPANY

DATE 8/28/2020

PCO #59 - INFLUENT STRUCTURE 12 INCH SI ABANDONMENT
NVWWTP - DOUGLAS COUNTY
RDC PROJECT # 18017

EQUIPMENT			
	HOURLY RATE	HOURS	SUBTOTAL
Work Truck	32.48	4.00	129.92

LABOR			
	HOURLY RATE	HOURS	SUBTOTAL
Superintendent	120.00	4.00	480.00
Project Manager	120.00	0.00	0.00
Sr. Project Engineer	120.00	0.00	0.00
Jr. Project Engineer	70.00	0.00	0.00
Operator - Roller	76.75	0.00	0.00
Operator - Loader	77.84	0.00	0.00
Operator - B/T/E	77.36	0.00	0.00
Carpenter	76.16	0.00	0.00
Laborer	47.54	8.00	380.32
Driver - Water	29.37	0.00	0.00
Driver - Dump/Transport	46.71	0.00	0.00
Shop Labor	78.00	0.00	0.00
Shop Welder	110.50	0.00	0.00
Travel		0.00	0.00
Subsistence	75.00	0.00	0.00

MATERIAL			
	MATERIAL COST	TAX	SUBTOTAL
Hardware	0.00	0.00	0.00
Material	0.00	0.00	0.00
	0.00	0.00	0.00
	0.00	0.00	0.00
	0.00	0.00	0.00
Consumables	0.00	0.00	0.00
Dump Fee	0.00	0.00	0.00
Freight	0.00	0.00	0.00

SUBCONTRACTOR		
	DIRECT COST	SUBTOTAL
	0.00	0.00
	0.00	0.00
	0.00	0.00
	0.00	0.00

TOTALS				
	SUBTOTAL	MARK-UP %	MARK-UP	TOTAL
Equipment	129.92	15%	19.49	\$ 149.41
Labor	860.32	15%	129.05	\$ 989.37
Material	0.00	15%	0.00	\$ -
Subcontractor	0.00	5%	0.00	\$ -
Bonds & Insurance (3%)	0.00	0%	0.00	\$ -

INCREASE IN CONTRACT TIME 0 DAYS

JOB TOTAL 1,138.78

Submitted By: Christopher Erb

REQUEST FOR INFORMATION FORM

NORTH VALLEY WASTEWATER TREATMENT PLANT IMPROVEMENTS



RESOURCE DEVELOPMENT COMPANY

SUBMITTED TO:	JEREMY WILSON	RFI #	117
	KELLER ASSOCIATES	DATE SUBMITTED:	8/17/2020
SUBMITTED BY:	Christopher Erb	DATE NEEDED:	8/24/2020
	RDC	RDC PROJECT #	18017

SPEC SECTION(S): 02 41 00 DEMOLITION

PLAN SHEET(S): 160-SM-2001

RFI DESCRIPTION:

On Sheet 160-SM-2001 Section A we are required to anchor bolt a plate to the vault wall to Abandoned the 12" SI pipe.

The issue is the existing pipe is not flush with the vault wall as indicated on the plans will require RDC to flush cut the pipe and grind the grout flush with the wall in order for the abandonment detail to work.

RDC views the removal of the pipe and grout as as extra work, and will provide PCO pricing once this RFI is responded to.

ATTACHMENTS: Picture of existing pipe penetration and sheet 160-SM-2001

RFI RESPONSE:

Proposed approach is acceptable.


RESPONSE BY:


Jeremy Wilson, PE

DATE: 08/25/2020

INFLUENT STRUCTURE EXISTING 12" SI PIPE PENETRATION





STRUCTURAL / MECHANICAL

AEROBIC DIGESTER PLAN

DESIGN OFFICE
2525 AIRPARK DRIVE
REDDING, CA 96001
(530) 243 5831

NORTH VALLEY WWTP
IMPROVEMENTS PROJECT
DOUGLAS COUNTY PUBLIC WORKS (DCWP)
DOUGLAS COUNTY, NV

NO.	DATE	REVISION	BY	APVD

DR: RANDALL / CORNWALL
CHK: D CAVE
T PAIGE / J RIFE

J DEHN

VERBITY SCALE

DATE: JUNE 2018

PROJECT: 106-SM-2001

SHEET: 31 OF 111

PROFESSIONAL SEAL

REGISTERED PROFESSIONAL ENGINEER

STATE OF NEVADA

NO. 100118

PROFESSIONAL SEAL

REGISTERED PROFESSIONAL MECHANICAL ENGINEER

STATE OF NEVADA

NO. 100118

REUSE OF DOCUMENTS: THIS DOCUMENT AND THE IDEAS AND DESIGN INCORPORATED HEREIN, AS AN INSTRUMENT OF PROFESSIONAL SERVICE IS THE PROPERTY OF CH2M HILL AND IS NOT TO BE USED, IN WHOLE OR IN PART, FOR ANY OTHER PROJECT WITHOUT THE WRITTEN AUTHORIZATION OF CH2M HILL. © CH2M HILL 2015. ALL RIGHTS RESERVED.



Work Change Directive

Owner:	Douglas County	WCD No.:	32
Project Name:	NVWWTP Improvements Project	Project No.:	216030
Contractor:	Resource Development Company	Issued By:	Jeremy Wilson
Attention:	Alex Nevarez	Date Issued:	09/25/2020

Reason for Change: The contractor’s schedule was impacted by the COVID-19 pandemic.

Description of change(s): A member of the Contractor’s staff contracted COVID-19 and was in close proximity to many members of the project team. To accommodate, the Contractor proceeded as indicated in the attached email chain. It is understood that this work change directive accounts for all COVID-19 related delays to date.

Attachments: Contractor’s proposed change order.

Contract Sum Adjustment: The proposed basis of adjustment to the Contract Sum or Guaranteed Maximum Price is (Place an X in the appropriate box).

No increase in contract cost is anticipated as part of this WCD.

- Lump Sum increase of
- Unit Price of
- Cost of Work not to exceed
- Contractor Submit TM Ticket

Contract Time Adjustment: An increase of **14 contract days** is anticipated as part of this WCD.

When signed by the Owner and Engineer authorized representatives and received by the Contractor, this document becomes effective immediately as a Construction Change Directive, and the Contractor shall proceed with the change(s) described above. The Contractor's signature, signed by an authorized representative, indicates agreement with the proposed adjustments in Contract Sum and Contract Time set forth in this Construction Change Directive.


Keller Associates, Inc.

Engineer

1325 Airmotive Way Suite 380

Reno, Nevada 89502

(Address)


By (Authorized Signature)

Jeremy Wilson

(Printed Name)

09/25/2020

Date


Douglas County

Owner

1120 Airport Road, Bldg F2

Minden, Nevada 89423

(Address)


By (Authorized Signature)

Philip Ritger

(Printed Name)

10-07-2020

Date


Resource Development Company

Contractor

1050 Linda Way

Sparks, Nevada 89431

(Address)


By (Authorized Signature)

Christopher Erb

(Printed Name)

10/08/20

Date



RESOURCE DEVELOPMENT COMPANY

PCO #58 – COVID-19 DAYS

Date: August 09, 2020

Project: NVWWTP Improvements

ATTN: Jeremy Wilson, PE – Keller Associates

Mr. Wilson,

This PCO is to document the process for equitable adjustment in Contract Times and Contract Price due to number of days that COVID-19 has delayed the project. See attached email notification from Friday August 17, 2020 indicating the anticipated delay.

PCO #52 Extra Work Total: \$801.99 Waved

Additional Contract Days: 14 Contract Days

Please don't hesitate to contact me if you have any questions or need any clarification.

Sincerely,

Christopher Erb

Christopher Erb

Resource Development Company

Cc: Ron Roman, PE – DCPW

 Scott McCullough - DCPW



RESOURCE DEVELOPMENT COMPANY

DATE 8/31/2020

PCO #58 - COVID-19 DAYS
DOUGLAS COUNTY
RDC PROJECT # 18017

EQUIPMENT			
	HOURLY RATE	HOURS	SUBTOTAL
Office Trailer	1.95	112.00	218.40
Engineer Office Trailer	1.95		0.00
Sanitary Facilities	1.25	112.00	140.00
Temp Power	1.70	112.00	190.40
Utilities	0.57	112.00	63.84
Connex	0.57	112.00	63.84

LABOR			
	HOURLY RATE	HOURS	SUBTOTAL
Superintendent	120.00	0.00	0.00
Project Manager	120.00	0.00	0.00
Sr. Project Engineer	120.00	0.00	0.00
Jr. Project Engineer	70.00	0.00	0.00
Operator - Roller	76.75	0.00	0.00
Operator - Loader (Crane)	77.84	0.00	0.00
Operator - B/T/E	77.36	0.00	0.00
Carpenter	76.16	0.00	0.00
Surveyor	76.16	0.00	0.00
Laborer	47.54	0.00	0.00
Driver - Water	29.37	0.00	0.00
Driver - Dump/Transport	46.71	0.00	0.00
Shop Labor	78.00	0.00	0.00
Shop Welder	110.50	0.00	0.00
Travel		0.00	0.00
Subsistence	75.00	0.00	0.00

MATERIAL			
	MATERIAL COST	TAX	SUBTOTAL
	0.00	0.00	0.00
Consumables	0.00	0.00	0.00
Dump Fee	0.00	0.00	0.00
Freight	0.00	0.00	0.00

SUBCONTRACTOR		
	DIRECT COST	SUBTOTAL
	0.00	0.00
	0.00	0.00
	0.00	0.00
	0.00	0.00

TOTALS				
	SUBTOTAL	MARK-UP %	MARK-UP	TOTAL
Equipment	676.48	15%	101.47	\$ 777.95
Labor	0.00	15%	0.00	\$ -
Material	0.00	15%	0.00	\$ -
Subcontractor	0.00	5%	0.00	\$ -
Bonds & Insurance (3%)	23.34	0%	0.00	\$ 23.34

INCREASE IN CONTRACT TIME 14 DAYS

JOB TOTAL 801.29

Submitted By: Christopher Erb

From: Chris Erb
To: Roman, Ron <RRoman@douglasnv.us>
Cc: Alex Nevarez; Jeremy Wilson; Ritger, Philip <PRitger@douglasnv.us>; Jeff Farr; Preciado, Peter
Subject: RE: COVID-19 (18017 NVWWTP Douglas County)
Date: Wednesday, August 26, 2020 2:30:00 PM

Ron

Thank you and yes that is correct we will have staff onsite tomorrow.

Chris Erb
RDC
775-842-0232

From: Roman, Ron <RRoman@douglasnv.us> <RRoman@douglasnv.us>
Sent: Wednesday, August 26, 2020 2:18 PM
To: Chris Erb <cerb@resourcedevelopmentco.com>
Cc: Alex Nevarez <anevarez@resourcedevelopmentco.com>; Jeremy Wilson <jwilson@Kellerassociates.com>; Ritger, Philip <PRitger@douglasnv.us> <PRitger@douglasnv.us>; Jeff Farr <jfarr@resourcedevelopmentco.com>; Preciado, Peter <ppreciado@douglasnv.us>
Subject: RE: COVID-19 (18017 NVWWTP Douglas County)

CAUTION: This email originated from outside your organization. Exercise caution when opening attachments or clicking links, especially from unknown senders.

Chris,

The County has no concerns with RDC returning to work on August 31, 2020. I also understand that you plan to have RDC staff at the NVWWTP tomorrow to remove the effluent pumps from the operations building.

Ron Roman
Engineering Manager
Douglas County Public Works
P.O. Box 218
1120 Airport Road
Minden, NV 89423

775-782-6239
775-690-3025 (C) **I am working remotely, please call on my cell number**

From: Chris Erb [mailto:cerb@resourcedevelopmentco.com]
Sent: Wednesday, August 26, 2020 6:22 AM
To: Roman, Ron <RRoman@douglasnv.us> <RRoman@douglasnv.us>
Cc: Alex Nevarez <anevarez@resourcedevelopmentco.com>; Jeremy Wilson <jwilson@Kellerassociates.com>; Ritger, Philip <PRitger@douglasnv.us> <PRitger@douglasnv.us>;

Jeff Farr <jfarr@resourcedevelopmentco.com>; Preciado, Peter <ppreciado@douglasnv.us>
Subject: RE: COVID-19 (18017 NVWWTP Douglas County)

CAUTION: This email is from an external source. Use caution when clicking links or opening attachments.

Ron

RDC has completed the recommended Quarantine period and has not received any positive COVID-19 tests from its employees indicating a need to extend the Quarantine period.

RDC has asked its employees effected by the "Close Contact" incident to return to work August 31, 2020 and intends to restart work at the NVWWTP site on this date.

Does Douglas County have any concerns with RDC proceeding with the work on this date?

Please call me if you have any questions.

Thanks
Chris Erb
RDC
775-842-0232

From: Roman, Ron <RRoman@douglasnv.us> <RRoman@douglasnv.us>
Sent: Wednesday, August 19, 2020 3:15 PM
To: Chris Erb <cerb@resourcedevelopmentco.com>
Cc: Alex Nevarez <anevarez@resourcedevelopmentco.com>; Jeremy Wilson <jwilson@kellerassociates.com>; Ritger, Philip <PRitger@douglasnv.us> <PRitger@douglasnv.us>; Jeff Farr <jfarr@resourcedevelopmentco.com>; Preciado, Peter <ppreciado@douglasnv.us>
Subject: RE: COVID-19 (18017 NVWWTP Douglas County)

Chris,

Thank you for the update on how RDC is proceeding on this issue. RDC is responsible for the safety and security of people working out at the site right now. If you have reason to believe that specific safety protocols are necessary or justified, then that is a call you will need to make. We don't currently have enough information to determine the reasonableness of your course of action. Please keep us informed as you have new information.

Ron Roman
Engineering Manager
Douglas County Public Works
P.O. Box 218
1120 Airport Road
Minden, NV 89423

775-782-6239

775-690-3025 (C) **I am working remotely, please call on my cell number**

From: Chris Erb <cerb@resourcedevelopmentco.com>

Sent: Monday, August 17, 2020 1:25 PM

To: Roman, Ron <RRoman@douglasnv.us> <RRoman@douglasnv.us>

Cc: Alex Nevarez <anevarez@resourcedevelopmentco.com>; Jeremy Wilson <jwilson@kellerassociates.com>; Ritger, Philip <PRitger@douglasnv.us> <PRitger@douglasnv.us>; Jeff Farr <jfarr@resourcedevelopmentco.com>; Pete Preciado (ppeciado@douglasnv.us) <ppeciado@douglasnv.us>; Rippe, Steve <SRippe@douglasnv.us>; Jim Andrews <jim@creekside-electric.com>

Subject: Re: COVID-19 (18017 NVWWTP Douglas County)

CAUTION: This email is from an external source. Use caution when clicking links or opening attachments.

Date correction on line 6. Should have been August 17, 2020 not August 24,2020.

Get Outlook for iOS

From: Chris Erb

Sent: Monday, August 17, 2020 12:58:29 PM

To: Roman, Ron

Cc: Alex Nevarez ; Jeremy Wilson ; Ritger, Philip ; Jeff Farr ; Pete Preciado (ppeciado@douglasnv.us) ; Steve Rippe (SRippe@douglasnv.us) ; Jim Andrews

Subject: RE: COVID-19 (18017 NVWWTP Douglas County)

Ron

In regards to the recent employee incident with COVID-19, RDC will be following the guidelines set about in the following documents:

1. https://www.cdc.gov/coronavirus/2019-ncov/if-you-are-sick/quarantine.html?CDC_AA_refVal=https%3A%2F%2Fwww.cdc.gov%2Fcoronavirus%2F2019-ncov%2Fif-you-are-sick%2Fquarantine-isolation.html

Who needs to quarantine?

People who have been in close contact with someone who has COVID-19—excluding people who have had COVID-19 within the past 3 months.

What counts as close contact?

- You were within 6 feet of someone who has COVID-19 for a total of 15 minutes or more
- You provided care at home to someone who is sick with COVID-19
- You had direct physical contact with the person (hugged or kissed them)
- You shared eating or drinking utensils
- They sneezed, coughed, or somehow got respiratory droplets on you

Steps to take

Stay home and monitor your health

- Stay home for 14 days after your last contact with a person who has COVID-19
 - Watch for fever (100.4°F), cough, shortness of breath, or other symptoms of COVID-19
 - If possible, stay away from others, especially people who are at higher risk for getting very sick from COVID-19
2. <https://www.cdc.gov/coronavirus/2019-ncov/testing/diagnostic-testing.html>
 3. Washoe County info: <https://covid19washoe.com/testing/>

Bellow is a short schedule that provides dates and the approach RDC will use to minimize any potential spread of COVID-19 at the NVWWTP site.

1. August 7, 2020 last day that the incident employee was onsite at Minden.
2. August 14, 2020 RDC is informed that the employee met the definition of Close Contact for COVID-19.
3. August 14, 2020 Employee was sent for testing.
4. August 14, 2020 All RDC Employees sent home from NVWWTP job site.
5. August 17, 2020 Employee reported that test came back negative. (RDC trying to confirm via official paperwork not received yet, also test result should be considered preliminary in that the recommendations are that a 14 day wait period be followed before testing, The employee may need to be tested again)
6. August 24, 2020 RDC will be stopping all onsite work until this 14 day criteria is met.
7. August 25, 2020 RDC will be tentatively restarting onsite work pending results of Testing.

Please call me if you have any questions.

Thanks
Chris Erb
RDC
775-842-0232

From: Roman, Ron
Sent: Friday, August 14, 2020 3:28 PM
To: Chris Erb
Cc: Alex Nevarez ; Jeremy Wilson ; Ritger, Philip
Subject: RE: COVID-19 (18017 NVWWTP Douglas County)

Chris,

We've provided notice to our employees that are working on the NVWWTP project. Please let me know when you have test results and additional information.

Ron Roman
Engineering Manager
Douglas County Public Works
P.O. Box 218
1120 Airport Road
Minden, NV 89423
775-782-6239

775-690-3025 (C) **I am working remotely, please call on my cell number**

From: Chris Erb <cerb@resourcedevelopmentco.com>

Sent: Friday, August 14, 2020 12:03 PM

To: Roman, Ron <RRoman@douglasnv.us> <RRoman@douglasnv.us>
Cc: Alex Nevarez <anevarez@resourcedevelopmentco.com>; Jeremy Wilson <jwilson@Kellerassociates.com>
Subject: COVID-19 (18017 NVWWTP Douglas County)

CAUTION: This email is from an external source. Use caution when clicking links or opening attachments.

Ron

Today RDC was informed by one of our employees who was working at the NVWWTP 2 weeks ago that they have had contact with a person that tested positive for COVID-19. As a result of this we have sent the employee for testing and are awaiting the results. Additionally as a precaution at this time, we have sent all NVWWTP workers home for the weekend as we await the results of the testing.

We will let you know more on how we will have to address this issue once we have more information.

Thanks

Christopher Erb, P.E.



1050 Linda Way

Sparks, NV 89431

775.356.8004 (office)

775.842.0232 (cell)

cerb@resourcedevelopmentco.com

Disclaimer

The information contained in this communication from the sender is confidential. It is intended solely for use by the recipient and others authorized to receive it. If you are not the recipient, you are hereby notified that any disclosure, copying, distribution or taking action in relation of the contents of this information is strictly prohibited and may be unlawful. This email has been scanned for viruses and malware, and may have been automatically archived by Mimecast.

Owner:	Douglas County	WCD No.:	33
Project Name:	NVWWTP Improvements Project	Project No.:	216030
Contractor:	Resource Development Company	Issued By:	Jeremy Wilson
Attention:	Alex Nevarez	Date Issued:	09/28/2020

Reason for Change: This WCD covers the labor, materials, equipment, and installation cost to provide a complete and functioning heat trace system for the project.

Description of change(s): This WCD includes removal/replacement/upsizing the transforming connecting BCP-151, installation of additional required breakers, conduits, conductors, potholing, and excavation in order to provide a complete and functioning heat trace system.

The parties were not able to come to a mutual agreement on a lump sum price to perform the work described in the attached PCO #35. In accordance with general conditions paragraph 11.04B, this work is to be performed on a time and materials basis. As the final cost of the work in PCO #35 is unknown at this time, the contractor is responsible for monitoring their costs and notifying the engineer prior to exceeding the authorized amount for this work.

Attachments: Contractor's proposed change order.

Contract Sum Adjustment: The proposed basis of adjustment to the Contract Sum or Guaranteed Maximum Price is (Place an X in the appropriate box).

- Lump Sum increase of
- Unit Price of
- Cost of Work not to exceed
- Contractor Submit TM Ticket \$56,204.99

Contract Time Adjustment: No increase in contract time is anticipated as part of this WCD.

When signed by the Owner and Engineer authorized representatives and received by the Contractor, this document becomes effective immediately as a Construction Change Directive, and the Contractor shall proceed with the change(s) described above. The Contactor's signature, signed by an authorized representative, indicates agreement with the proposed adjustments in Contract Sum and Contract Time set forth in this Construction Change Directive.


Keller Associates, Inc.

Engineer

1325 Airmotive Way Suite 380

Reno, Nevada 89502

(Address)



By (Authorized Signature)

Jeremy Wilson

(Printed Name)

09/28/2020

Date


Douglas County

Owner

1120 Airport Road, Bldg F2

Minden, Nevada 89423

(Address)



By (Authorized Signature)

Philip Ritger

(Printed Name)

09-29-2020

Date

Resource Development Company

Contractor

1050 Linda Way

Sparks, Nevada 89431

(Address)



By (Authorized Signature)

CHRISTOPHER ERB

(Printed Name)

09/30/20

Date



RESOURCE DEVELOPMENT COMPANY

PCO #35 – Heat Trace Revisions

Date: June 24, 2020 Revised August 11, 2020

Project: NVWWTP Improvements

ATTN: Jeremy Wilson, PE – Keller Associates

Mr. Wilson,

Resource Development Company (RDC) offers the following change proposal for heat trace and insulation extra work in response to RFI #92, RFI #92-2 and RFI #92-3. Scope of work includes: PCO coordination, heat trace circuit layout, remove and replace/upsized transformer feeding panel BCP-151, install additional required circuits (breakers, conduit & conductors), potholing, excavation, backfill, finish grade & type II surfacing, heat trace controller and complete heater set at sludge dewatering pad, testing, start-up and as-builts.

PCO #35 Extra Work Total: \$68,072.99

Additional Contract Days: 21 Calendar Days

Clarifications

1. Conduit routing for the additional heat trace circuit at the sludge dewatering pad is assumed to be as shown on the attached schematic. Please advise if alternate conduit routing is desired.

Please don't hesitate to contact me if you have any questions.

Thank you,

Christopher Erb

Christopher Erb
Resource Development Company

Cc: Ron Roman, PE – DCPW
Scott McCullough – DCPW

Attachments: Digested Solids Conduit Routing Schematic
Reference: RFI #92-1, RFI #92-2, RFI #92-3

1050 Linda Way Sparks, NV 89431-5598
(775) 356-8004 / Fax (775) 356-0610
Nevada License No. 75026 / California License No. 893537



RESOURCE DEVELOPMENT COMPANY

DATE 8/11/2020

**PCO #35- HEAT TRACE REVISIONS
NWWWTP - DOUGLAS COUNTY
RDC PROJECT # 18017**

EQUIPMENT	HOURLY RATE	HOURS	SUBTOTAL
900 Air Compressor	72.47	0.00	0.00
375 Air Compressor	29.90	0.00	0.00
185 Air Compressor	16.81	0.00	0.00
125 KW Generator	42.43	0.00	0.00
45 KW Generator	12.04	0.00	0.00
Mini Ex John Deere 50	25.23	8.00	201.84
Hitachi 120 Excavator	55.77	0.00	0.00
Hitachi 200 Excavator	66.02	0.00	0.00
Backhoe 310 SE	39.60	0.00	0.00
Loader	74.41	0.00	0.00
Skid Steer	21.74	16.00	347.84
Sheepsfoot Roller	34.83	0.00	0.00
Smooth Drum Roller	34.83	8.00	278.64
Frostfighter Heater	30.00	0.00	0.00
Dehumidifier	37.43	0.00	0.00
Sandblasting Equipment	3.04	0.00	0.00
Rammax Compactor	17.00	8.00	138.00
Dust Collector	73.87	0.00	0.00
Boom Lift	32.40	0.00	0.00
Reach Fork BK	37.47	0.00	0.00
Reach Fork 10K	51.26	0.00	0.00
Scissor Lift	28.58	0.00	0.00
Light Truck	24.98	0.00	0.00
Work Truck	32.48	46.00	1,484.08
Water Truck	39.86	0.00	0.00
Transport	60.45	16.00	967.20
28 Ton Crane - Grove	79.69	0.00	0.00
Office Trailer	1.95	46.00	89.70
Engineer Office Trailer	1.95	0.00	0.00
Sanitary Facilities	1.25	46.00	57.50
Temp Power	1.70	46.00	78.20
Utilities	0.57	0.00	0.00
Connex	0.57	46.00	26.22
Survey Equipment	10.00	6.00	60.00
Confined Space Equipment	5.00	0.00	0.00
Scaffold (5' section)	0.54	0.00	0.00
Whacker	8.41	0.00	0.00
Fuel Storage Tank	1.00	0.00	0.00
End Dump Trailer	6.13	4.00	24.52
Dewatering Equipment	3.00	0.00	0.00

LABOR	HOURLY RATE	HOURS	SUBTOTAL
Superintendent	120.00	17.00	2,040.00
Project Manager	120.00	21.50	2,580.00
Sr. Project Engineer	120.00	88.00	10,320.00
Jr. Project Engineer	70.00	0.00	0.00
Operator - Roller	76.75	0.00	0.00
Operator - Loader (Crane)	77.84	0.00	0.00
Operator - B/T/E	77.36	27.00	2,088.72
Carpenter	76.16	0.00	0.00
Surveyor	76.16	4.00	304.64
Laborer	47.54	78.00	3,708.12
Driver - Water	29.37	0.00	0.00
Driver - Dump/Transport	46.71	16.00	747.36
Shop Labor	78.00	0.00	0.00
Shop Welder	110.50	0.00	0.00
Travel	0.00	0.00	0.00
Subsistence	75.00	0.00	0.00

MATERIAL	MATERIAL COST	TAX	SUBTOTAL
Heater Cable	0.00	0.00	0.00
T-Stat	0.00	0.00	0.00
Termination Kit	0.00	0.00	0.00
Heat Trace Accessories	0.00	0.00	0.00
Pump Insulation Materials	575.00	43.70	618.70
Type II Base	259.26	19.70	278.96
Consumables	0.00	0.00	0.00
Dump Fee	0.00	0.00	0.00
Freight	0.00	0.00	0.00


SUBCONTRACTOR	DIRECT COST	SUBTOTAL
Creekside Electric	33976.00	33,976.00
	0.00	0.00
	0.00	0.00
	0.00	0.00

TOTALS	SUBTOTAL	MARK-UP %	MARK-UP	TOTAL
Equipment	3781.74	15%	564.26	\$ 4,326.00
Labor	21788.84	15%	3268.33	\$ 25,057.17
Material	897.66	15%	134.65	\$ 1,032.31
Subcontractor	33976.00	5%	1698.80	\$ 35,674.80
Bonds & Insurance (3%)	1982.71	0%	0.00	\$ 1,982.71

INCREASE IN CONTRACT TIME	21 DAYS
---------------------------	---------

JOB TOTAL	68,072.99
-----------	-----------

Submitted By: Christopher Erb



DIGESTED SLUDGE HEAT TRACE POWER CONDUIT ROUTING CONCEPT

SCHEMATIC

CREEKSIDE ELECTRICAL CONTRACTORS, INC.

3059 Airport Road Carson City, NV 89706
 Ph: (775) 841-5558 Fax: (775) 841-5565
 NV Lic. # 50401 CA Lic. # 915754 DBE#NV01193UCPN

CHANGE ORDER REQUEST

#007

Proposal Submitted to:

Resource Development Company

JOB:

NVWWT Treatment Plant
 Improvements

Work Description:

Furnish and install conduit, boxes, fittings, supports, wire, circuit breakers, transformer and terminations for plant heat trace at Headworks, SBR-1 & SBR-2, Influent Pump Station and Sludge Dewatering Pad.

Proposal based on response to RFI# 92-2 by Keller Engineering and CAD drawings provided by RDC.

THE ABOVE SUBJECT AGREEMENT IS HEREBY CHANGED AS FOLLOWS:

ITEM NO.	DESCRIPTION OF CHANGE	ADD	DEDUCT
1	See attached Material and Labor Breakdown	\$33,977.00	

Contract Amount	This Change Order		Revised Contract Amount
	Add	Deduct	
\$1,299,300.00	\$33,977.00		\$1,333,277.00

Except as modified by this Change Order (and previous Change Orders, if any) the subject agreement remains unchanged and continues in full force and effect.

Please sign and return the original of this Change Order.

Material & Work will not begin until an executed change order has been received by this office.

By: _____
 Title: _____
 Date: _____

By: Jim Andrews PM
 Date: 3/25/2020

CREEKSIDE ELECTRICAL CONTRACTORS, INC.

3059 Airport Road
 Carson City, Nevada 89706
 Phone 775-841-5558 Fax 775-881-5565
 NV License No. 50401 CA License No. 915754

MATERIAL AND LABOR PROPOSAL BREAKDOWN

PROPOSAL DATE: 3/25/2020 **COR#:** 7
JOB #: #12-18 **NAME:** NVWWTP Improvements
DESCRIPTION: Furnish and install conduit, wire, boxes, fittings, breakers, transformer and supports to connect site heat trace at Headworks, SBR-1 & SBR-2, Influent Pump Station and Sludge Dewatering Pad per RFI# 92-2.

A. MATERIAL & EQUIPMENT \$11,463.00
 Tax %: 7.10% \$813.87
 M & E Subtotal \$12,276.87

B. LABOR

	RATE	MANHOURS	AMOUNT
Foreman-Electrical	\$93.50	28	\$2,618.00
Journeyman-Electrical	\$85.00	95	\$8,075.00
Apprentice-Electrical	\$65.00	95	\$6,175.00
Shop	\$50.00		\$0.00
Labor Subtotal			<u>\$16,868.00</u>

C. FIELD RELATED COSTS

Clean Up	\$ _____
Material Handling	\$ _____
As Builts/Plans	\$ _____
Permits	\$ _____
Consumable Material	\$ _____
Tools	\$ _____
Truck Charges	\$ 400.00
Travel/Per Diem	\$ _____
Shipping/Restock	\$ _____
Equipment Rental	\$ _____
Labor Subtotal	<u>\$400.00</u>

SUBTOTAL \$29,544.87

D. SUBCONTRACT COST	%	\$0.00
E. SUBCONTACT MARK-UI	%	\$0.00
F. OFFICE OVERHEAD	5.00%	\$1,477.24
G. PROFIT	10.00%	\$2,954.49

COST & MARK-UP SUBTOTAL \$33,976.60

PROPOSAL SUBTOTAL \$33,976.60

H. BOND \$ _____

TOTAL PROPOSAL AMOUNT \$33,976.60

REQUEST FOR INFORMATION FORM

NORTH VALLEY WASTEWATER TREATMENT PLANT IMPROVEMENTS



RESOURCE DEVELOPMENT COMPANY

SUBMITTED TO:	JEREMY WILSON	RFI #	92 - 3
	KELLER ASSOCIATES	DATE SUBMITTED:	3/19/2020
SUBMITTED BY:	CHRIS ERB	DATE NEEDED:	3/26/2020
	RDC	RDC PROJECT #	18017

SPEC SECTION(S): 40 05 33

PLAN SHEET(S): 200-E-2110, 2120, 2121, 6001

RFI DESCRIPTION:

This is a follow-up to RFI #92-2, and is submitted in conjunction with submittal 400533-01 - Pipe Heat Tracing.

QUESTION FROM CREEKSIDE:

The engineer has upsized feeder breaker, transformer and BCP-150 main circuit breaker, but did not upsize panel BCP-151 where all the added circuits are being supplied. It is still being fed by a 60A circuit breaker from BCP 150.

Can you check on this and make sure he didn't miss upsizing this panel?

RESPONCE FROM KELLER/JACOBS:

We have confirmation from Jacobs. BCP-151 is OK as is. (EMAIL 03/10/20 ATTACHED)

As mentioned in RFI #92 and RFI #92-2, RDC views much of this as extra work, and will provide PCO pricing once the requested electrical design information is provided, and the heat trace submittal is approved.

RFI #92-2 - Heat Trace Circuits attached for reference.

Question from Creekside: Load Data, Heat Trace Layout Schematics, RFI #92, Heat Trace Layout Schematics, RFI #92-2,

RFI RESPONSE:

RESPONSE BY:

DATE:

REQUEST FOR INFORMATION FORM

NORTH VALLEY WASTEWATER TREATMENT PLANT IMPROVEMENTS



RESOURCE DEVELOPMENT COMPANY

SUBMITTED TO:	JEREMY WILSON	RFI #	92 - 2
	KELLER ASSOCIATES	DATE SUBMITTED:	1/27/2020
SUBMITTED BY:	CHRIS ERB	DATE NEEDED:	2/3/2020
	RDC	RDC PROJECT #	18017

SPEC SECTION(S): 40 05 33

PLAN SHEET(S): 200-E-2110, 2120, 2121, 6001

RFI DESCRIPTION:

This is a follow-up to RFI #92, and is submitted in conjunction with submittal 400533-01 - Pipe Heat Tracing.

Per the approved design, provisions for heat trace only includes two (2) non-GFCI 120V 300W (VA) circuits from Panel BCP-151 (circuits 11 & 15 on plan sheet 200-E-6001). Heat trace load requirements (see attached) are substantially higher than provisioned on the contract drawings, and may overload the panel(s), as designed. Please provide panel designation (added or upsize panel if needed), breaker configuration, and circuit numbers to accommodate the actual heat trace circuit loads. Note that one additional circuit was added at the SBR to distribute heater loading, now four (4) circuits are required at the SBR, as opposed to three (3) circuits indicated in the original RFI #92.

Based on the amount of exposed high importance process piping on the north side of the SBR, RDC recommends a conservative design.

Specifications don't call for lighted end seal terminations for exposed piping. Please advise if lighted end seals are desired for exposed piping.

As mentioned in RFI #92, RDC views much of this as extra work, and will provide PCO pricing once the requested electrical design information is provided, and the heat trace submittal is approved.


Attachments Load Data, Heat Trace Layout Schematics, RFI #92,

RFI RESPONSE:

Provide heat trace circuits from panel BCP-151. Change breakers to those as proposed. See attached recommendation for layout. Lighted end seal terminations are not required but may be an owner preference. Contractor confirm with owner if these are desired for exposed piping. Overall heat trace design appears to be adequate. Contractor confirm spiral method of tracing is being used on larger pipe per spec. Contractor confirm small pipe (1/2" PVC drain pipe) will only have one strip of heat trace. These added loads will require transformer up sizing for BCP-150. Please provide and install the following:

- Increase the 50A transformer BCP-150 feeder breaker in SWBD-150 to 70A
- Increase transformer BCP-150 from 30KVA to 45KVA
- Increase the main breaker in BCP-150 from 100A to 125A
- Increase related wiring and conduit as required.

RESPONSE BY:


Adam Neiwert, P.E.
Keller Associates

DATE: 2/26/2020

CIRCUIT TITLE	BREAKER					CIRCUIT TITLE
	NO	AMP	POLE	A	B	
PHASE A LOAD (VA)	1400					
PHASE B LOAD (VA)	1600					
PHASE C LOAD (VA)	1600					
TOTAL LOAD (VA)	4600					

CIRCUIT TITLE	BREAKER					CIRCUIT TITLE
	NO	AMP	POLE	A	B	
PHASE A LOAD (VA)	710					
PHASE B LOAD (VA)	870					
PHASE C LOAD (VA)	720					
TOTAL LOAD (VA)	2300					

BCP-150 PANEL BOARD SCHEDULE

BCP-180 PANEL BOARD SCHEDULE

CIRCUIT TITLE	BREAKER					CIRCUIT TITLE
	NO	AMP	POLE	A	B	
PHASE A LOAD (VA)	1400					
PHASE B LOAD (VA)	1600					
PHASE C LOAD (VA)	1600					
TOTAL LOAD (VA)	4600					

CIRCUIT TITLE	BREAKER					CIRCUIT TITLE
	NO	AMP	POLE	A	B	
PHASE A LOAD (VA)	810					
PHASE B LOAD (VA)	900					
PHASE C LOAD (VA)	890					
TOTAL LOAD (VA)	2600					

BCP-150 PANEL BOARD SCHEDULE

BCP-151 PANEL BOARD SCHEDULE

PANELBOARD SCHEDULE

PANEL: BCP-150
 RACK TYPE: 30X120X200, 3PH, 4W
 MAIN SIZE: 150
 INDOOR/OUTDOOR: 27-20001

PANEL: BCP-180
 RACK TYPE: 30X120X200, 3PH, 4W
 MAIN SIZE: 150
 INDOOR/OUTDOOR: 27-20001

PANEL: BCP-151
 RACK TYPE: 30X120X200, 3PH, 4W
 MAIN SIZE: 150
 INDOOR/OUTDOOR: 27-20001



DESIGN OFFICE
 2525 AIR PARK DRIVE
 REDDING, CA 96001
 (530) 243 5331

NORTH VALLEY WWTP
 IMPROVEMENTS PROJECT
 DOUGLAS COUNTY PUBLIC WORKS (DCPW)
 DOUGLAS COUNTY, NV

NO.	DATE	REVISION	BY	APVD
DSGN				
DR				
CHK				
APVD				


VERIFY SCALE
 DATE: JAN 2018
 PROJ: 200-C-63001
 DWG: 200-C-63001
 SHEET: 108 OF 111
 PLOT TIME: 13:22 PM

THIS DOCUMENT, AND THE DEED AND DEEDS INCORPORATED BY REFERENCE THEREIN, IS THE PROPERTY OF CH2M HILL AND IS NOT TO BE USED, IN WHOLE OR IN PART, FOR ANY OTHER PROJECT WITHOUT THE WRITTEN AUTHORIZATION OF CH2M HILL. © CH2M HILL 2015. ALL RIGHTS RESERVED.

Zone/Circuit	Circuit Breaker Size (A)*	Voltage (VAC)	Heater Cable	Operating Current (A) @ 40 F Maintenance Temp	Operating Load (W) @ 40 F Maintenance Temp	Operating Current (A) @ 50 F Maintenance Temp	Operating Load (W) @ 50 F Maintenance Temp	Maximum Current (A) @ 0 F Start-up	Maximum Current (A) @ 40F Start-up	Location
ZONE A1	30	208	BSX 6-2	14.7	2311	13.5	2683	22.3	16.6	SSR
ZONE A2	30	208	BSX 6-2	10.2	2126	9.4	1951	15.4	11.5	SSR
ZONE B	30	208	BSX 6-2	12.6	2609	11.5	2393	18.9	14.1	SSR
ZONE C	20	208	BSX 4-2	14.5	2872	13.3	2847	21.9	16.3	SSR
ZONE D	20	208	BSX 4-2	6.4	1395	5.9	1225	9.7	7.2	HEADWORKS
ZONE E	20	208	BSX 4-2	2.1	427	1.9	392	3.1	2.3	SLUDGE DRY PAD
ZONE F	20	120	BSX 5-1	0.8	100	0.8	91	1.4	1	INFLUENT PUMP STATION

*Recommended circuit break size. Engineer to advise if smaller breakers are desired.


COPY








LEGEND

- TEES/SPICE CONNECTION
- END TERMINATION
- × I-STAT
- ZONE M-1 BSX B-2 HEATER
- ZONE M-2 BSX B-2 HEATER
- ZONE B- BSX B-2 HEATER
- ZONE C- BSX B-2 HEATER
- SOLID WIRE IN CONDUIT


**NORTH SBR
HEAT TRACE LAYOUT
SCHEMATIC**




LEGEND

-  TEES/PLICE CONNECTION
-  END TERMINATION
-  T-STAT
-  ZONE 'D' BSX 8-2 HEATER
-  SOLID WIRE IN CONDUIT

HEADWORKS HEAT TRACE LAYOUT SCHEMATIC






1-1/2" W3
SST (TYPICAL)



LEGEND

- END TERMINATION
- ☒ T-STAT
- ZONE 1" BSX 5-1 HEATER
- ZONE 1" BSX 8-2 HEATER



**INFLUENT PUMP STATION
HEAT TRACE LAYOUT
SCHEMATIC**

**SLUDGE DEWATERING PAD
HEAT TRACE LAYOUT
SCHEMATIC**



REQUEST FOR INFORMATION FORM

NORTH VALLEY WASTEWATER TREATMENT PLANT IMPROVEMENTS



RESOURCE DEVELOPMENT COMPANY

SUBMITTED TO: JEREMY WILSON
KELLER ASSOCIATES

RFI #	92
DATE SUBMITTED:	11/8/2019
DATE NEEDED:	11/15/2019
RDC PROJECT #	18017

SUBMITTED BY: Chris Erb
RDC

SPEC SECTION(S): 40 05 33

PLAN SHEET(S): 200-E-2110, 2120, 2121 & 6001

RFI DESCRIPTION:


See attached RFI Description

Attachments

Preliminary Heat Trace Layout, Preliminary Heat Trace Calculations, Misc. Plan Sheet Excerpts, Misc. Product Data Sheets and Excerpts

RFI RESPONSE:

RESPONSE BY:


[Signature]

DATE: 12/3/2019

SBR and Headworks Exposed Piping Heat Trace

Proposed approach is acceptable in concept. Contractor provide action submittals for engineer review in accordance with specification 40 05 33.

Utility Water Pumps


Heat trace and insulation is desired for this location. Contractor provide action submittals for engineer review in accordance with specification 40 05 33.

Digested Solids (DS) Pipe Freeze Protection

Heat trace and insulation is desired for this location. Contractor provide action submittals for engineer review in accordance with specification 40 05 33.

Vent and Drain Piping at Air Release Valves (ARV)

Heat trace and insulation is desired for this location. Contractor provide action submittals for engineer review in accordance with specification 40 05 33.



RFI Description

SBR & Headworks Exposed Piping Heat Trace

Heat trace circuits included on the plans (two (2) 120V 20A circuits) are insufficient based on initial load calculations provided by the heat trace designer. The designer recommends utilizing 208V heat trace circuits, in lieu of 120V circuits, in order to minimize the total number of circuits required from approximately nine (9+/-) 120V circuits to four (4) 208V. The most cost-effective solution would utilize existing conduits (if possible) routed to existing heat tape connection points identified on the plans. Action submittals will be prepared and submitted following resolution of this RFI.

Heat Trace Designer Circuit Recommendations

- Location: North SBR (Zones A, B & C on the attached Preliminary Heat Trace Layout)
 - Recommendation: Three (3) 208V 30A Circuits

- Location: Headworks (Zone D on the attached Preliminary Heat Trace Layout)
 - Recommendation: One (3) 208V 20A Circuit

Note: This circuit could remain 120V, but for safety and for ease of future maintenance it is recommended that all heat trace circuits utilize the same voltage (208V recommended) and corresponding heater cable consistently throughout.

RDC views the electrical portion of the revisions from the panel board to the power connection points shown on the plans, as extra work (i.e. revised/additional circuit breakers, additional conductors and additional conduits (if any)). Field wiring, components and surface mount conduit required for the installation is RDC's responsibility and not considered extra work.

Utility Water Pumps

No freeze protection (insulation or heat trace) is provided for in the plans and specifications for the utility water pumps. Please advise if heat trace and/or insulation is desired for the utility water pumps 130-PMP-110 & 130-PMP-120.

RDC views any insulation and heat trace for the utility water pumps as extra work.


Digested Solids (DS) Pipe Freeze Protection

No heat trace circuits are included for the digested solids discharge piping at the sludge dewatering pad. Please advise if heat trace and/or insulation is desired at this location.

Heat trace at this location would be considered extra work.

Vent and Drain Piping at Air Release Valves (ARV)

Please confirm heat trace and/or insulation is required for all exposed ARV vent and drain piping on the north side of the SBR. RDC assumes both heat trace and insulation are required for all small diameter ARV vent and drain piping as shown on the attached "North SBR Preliminary Heat Trace Layout Schematic". Please advise if the any of these pipes should not be insulated or heat traced.



- LEGEND**
- TEE CONNECTION
 - △ END TERMINATION
 - ▽ T-SPLIT
 - ZONE 'X' BSX 8-2 HEATER
 - ZONE 'B' BSX 8-2 HEATER
 - ZONE 'C' BSX 8-2 HEATER
 - SOLID WIRE IN CONDUIT

**NORTH SBR
PRELIMINARY HEAT TRACE LAYOUT
SCHEMATIC**










ZONE 02 T-STAT
LOCATE ADJ. TO POWER
CONNECTION POINT

1-1/2" W3
SST (TYPICAL)

LEGEND

-  TEE CONNECTION
-  END TERMINATION
-  T-STAT
-  ZONE 02 BSX 8-2 HEATER
-  SOLID WIRE IN CONDUIT

HEADWORKS PRELIMINARY HEAT TRACE LAYOUT SCHEMATIC






TABLE 1
ELECTRICAL PANELBOARD SCHEDULE

NO.	DESCRIPTION	VOLTS	PHASES	TERMINALS	TYPE	REMARKS
1	400 AMP 480V 3PH 4W	480	3	40	ALUMINUM	
2	200 AMP 480V 3PH 4W	480	3	20	ALUMINUM	
3	100 AMP 480V 3PH 4W	480	3	10	ALUMINUM	
4	50 AMP 480V 3PH 4W	480	3	5	ALUMINUM	
5	25 AMP 480V 3PH 4W	480	3	2.5	ALUMINUM	
6	12.5 AMP 480V 3PH 4W	480	3	1.25	ALUMINUM	
7	6.25 AMP 480V 3PH 4W	480	3	0.625	ALUMINUM	
8	3.125 AMP 480V 3PH 4W	480	3	0.3125	ALUMINUM	
9	1.5625 AMP 480V 3PH 4W	480	3	0.15625	ALUMINUM	
10	0.78125 AMP 480V 3PH 4W	480	3	0.078125	ALUMINUM	
11	0.390625 AMP 480V 3PH 4W	480	3	0.0390625	ALUMINUM	
12	0.1953125 AMP 480V 3PH 4W	480	3	0.01953125	ALUMINUM	
13	0.09765625 AMP 480V 3PH 4W	480	3	0.009765625	ALUMINUM	
14	0.048828125 AMP 480V 3PH 4W	480	3	0.0048828125	ALUMINUM	
15	0.0244140625 AMP 480V 3PH 4W	480	3	0.00244140625	ALUMINUM	
16	0.01220703125 AMP 480V 3PH 4W	480	3	0.001220703125	ALUMINUM	
17	0.006103515625 AMP 480V 3PH 4W	480	3	0.0006103515625	ALUMINUM	
18	0.0030517578125 AMP 480V 3PH 4W	480	3	0.00030517578125	ALUMINUM	
19	0.00152587890625 AMP 480V 3PH 4W	480	3	0.000152587890625	ALUMINUM	
20	0.000762939453125 AMP 480V 3PH 4W	480	3	0.0000762939453125	ALUMINUM	

ELECTRICAL PANELBOARD SCHEDULE



UPPER PLAN

LOWER PLAN



PRODUCT SPECIFICATIONS

BSX™ SELF-REGULATING HEATING CABLE

APPLICATION


BSX self-regulating heating cables are designed to provide freeze protection or process temperature maintenance to metallic and nonmetallic piping, tanks and equipment. The heat output of BSX cable varies in response to the surrounding conditions along the entire length of a circuit. Whenever the heat loss of the insulated pipe, tank or equipment increases (as ambient temperature drops), the heat output of the cable increases. Conversely, when the heat loss decreases (as the ambient temperature rises or product flows), the cable reacts by reducing its heat output. BSX cables are approved for use in ordinary (nonclassified) areas and hazardous (classified) areas.

RATINGS

Available watt densities	3, 5, 8, 10 w/ft @ 50°F
	(10, 16, 26, 33 W/m @ 10°C)
Supply voltages	110-120 or 208-277 Vac
Max. maintenance temperature.....	150°F (65°C)
Max. continuous exposure temperature	
Power-off.....	185°F (85°C)
Minimum installation temperature.....	-60°F (-51°C)
Minimum bend radius	
@ 5°F (-15°C)	0.38" (10mm)
@ -76°F (-60°C)	1.25" (32 mm)
T-rating ¹	
3, 5, 8 w/ft (10, 16, 26 W/m).....	T6 185°F (85°C)
10 w/ft (33 W/m).....	T5 212°F (100°C)

Notes

1. T-rating per the National Electrical Code and Canadian Electrical Code.



CONSTRUCTION

- 1 Nickel-plated copper bus wires (16 AWG)
- 2 Radiation cross-linked semiconductive heating matrix
- 3 Radiation cross-linked dielectric insulation
- 4 Tinned copper braid
- 5 Polyolefin overjacket provides additional protection for cable and braid where exposure to aqueous inorganic chemicals is expected.

OPTIONS

- 6 FOJ Fluoropolymer overjacket over tinned copper braid provides additional protection to cable and braid where exposure to organic chemicals or corrosives is expected.

BASIC ACCESSORIES

Thermon offers system accessories designed specifically for rapid, trouble-free installation of Thermon heating cables.

All cables require a connection kit to comply with approval requirements. Information on accessories to complete a heater circuit installation can be found in the "Heating Cable Systems Accessories" product specification sheet (Form TEP0010).

THERMON The Heat Tracing Specialists®



Corporate Headquarters: 100 Thermon Dr • PO Box 609 San Marcos, TX 78667-0609 • Phone: 512-396-5801 • 1-800-820-4328
For the Thermon office nearest you visit us at . . . www.thermon.com




BSX™ SELF-REGULATING HEATING CABLE

POWER OUTPUT CURVES ¹

The power outputs shown apply to cable installed on insulated metallic pipe (using the procedures outlined in IEEE 515) at the service voltages stated below. For use on other service voltages, contact Thermon.

Catalog Number 120 Vac Nominal	Catalog Number 240 Vac Nominal	Power Output at 50°F (10°C) w/ft (m)
BSX 3-1	BSX 3-2	3 (10)
BSX 5-1	BSX 5-2	5 (16)
BSX 8-1	BSX 8-2	8 (26)
BSX 10-1	BSX 10-2	10 (33)



CIRCUIT BREAKER SIZING ²

Maximum circuit lengths for various circuit breaker amperages are shown below. Breaker sizing should be based on the National Electrical Code, Canadian Electrical Code or any other applicable code. The National Electrical Code and Canadian Electrical Code require ground-fault protection of equipment for each branch circuit supplying electric heating equipment. Check local codes for ground-fault protection requirements.

120 Vac Service Voltage		Max. Circuit Length ³ vs. Breaker Size ft (m)		
Catalog Number	Start-Up Temperature °F (°C)	20A	30A	40A
BSX 3-1	50 (10)	360 (110)	360 (110)	360 (110)
	0 (-18)	325 (99)	360 (110)	360 (110)
	-20 (-29)	285 (87)	360 (110)	360 (110)
BSX 5-1	-40 (-40)	260 (79)	360 (110)	360 (110)
	50 (10)	240 (73)	300 (91)	300 (91)
	0 (-18)	205 (62)	300 (91)	300 (91)
BSX 8-1	-20 (-29)	185 (56)	275 (84)	295 (90)
	-40 (-40)	165 (50)	250 (76)	265 (81)
	50 (10)	190 (58)	240 (73)	240 (73)
BSX 10-1	0 (-18)	150 (46)	225 (69)	240 (73)
	-20 (-29)	135 (41)	200 (61)	240 (73)
	-40 (-40)	120 (37)	180 (55)	215 (66)
BSX 3-2	50 (10)	160 (49)	200 (61)	200 (61)
	0 (-18)	110 (34)	170 (52)	200 (61)
	-20 (-29)	100 (30)	150 (46)	200 (61)
BSX 5-2	-40 (-40)	90 (27)	135 (41)	180 (55)

CERTIFICATIONS/APPROVALS



FM Approvals
Ordinary Locations
Hazardous (Classified) Locations
Class I, Division 2, Groups B, C and D
Class II, Division 2, Groups F and G
Class III, Divisions 1 and 2
Class I, Zones 1 and 2, AEx e II



Underwriters Laboratories Inc.
Ordinary Locations
Hazardous (Classified) Locations
Class I, Division 2, Groups A, B, C and D
Class II, Division 2, Groups F and G
Class III, Divisions 1 and 2



Canadian Standards Association
Ordinary Locations
Hazardous (Classified) Locations
Class I, Divisions 1 & 2, Groups A, B, C and D
Class II, Divisions 1 & 2, Groups E, F and G
Ex e II

208V

240 Vac Service Voltage		Max. Circuit Length ³ vs. Breaker Size ft (m)		
Catalog Number	Start-Up Temperature °F (°C)	20A	30A	40A
BSX 3-2	50 (10)	725 (221)	725 (221)	725 (221)
	0 (-18)	650 (198)	725 (221)	725 (221)
	-20 (-29)	575 (175)	725 (221)	725 (221)
BSX 5-2	-40 (-40)	515 (157)	725 (221)	725 (221)
	50 (10)	480 (146)	600 (183)	600 (183)
	0 (-18)	395 (120)	590 (180)	600 (183)
BSX 8-2	-20 (-29)	350 (107)	525 (160)	590 (180)
	-40 (-40)	315 (96)	475 (145)	530 (162)
	50 (10)	385 (117)	480 (146)	480 (146)
BSX 10-2	0 (-18)	285 (87)	425 (130)	480 (146)
	-20 (-29)	255 (78)	380 (122)	480 (146)
	-40 (-40)	230 (70)	345 (116)	430 (131)
BSX 3-1	50 (10)	280 (85)	400 (122)	400 (122)
	0 (-18)	225 (69)	340 (104)	400 (122)
	-20 (-29)	200 (61)	300 (91)	400 (122)
BSX 5-1	-40 (-40)	180 (55)	275 (84)	365 (111)

Notes

- For more precise power output values as a function of pipe temperature, refer to CompuTrace®.
- Based on the trip current characteristic of Type QOB or Type QO equipment protection devices. For devices with other trip current characteristics, contact Thermon.
- The maximum circuit length is for one continuous length of cable, not the sum of segments of cable. Refer to CompuTrace® design software or contact Thermon for current loading of segments.

HEAT TRACING DESIGN OUTLINE

The five steps below outline the design and selection process for an electric heat tracing system. The step-by-step procedures that follow the outline will provide the reader with the detailed information required to design, select and/or specify a fully functional electrical heat tracing system.

Step 1: Establish Design Parameters

Collect relevant project data:

- a. Piping/equipment
 - Diameter — Length — Material¹
- b. Temperature
 - Low ambient — Start-up temperature
 - Maintain temperature
 - High temperature — Limits/excursions
- c. Insulation
 - Type — Thickness — Same Size/Oversized?
- d. Electrical
 - Operating voltage — Circuit breaker capacity
 - Electrical area classification

Step 2: Determine Heat Losses

Using information gathered in Step 1 and based on:

- a. Heat loss charts/tables
- b. Computer design programs — CompuTrace

Step 3: Select the Proper Thermon Heating Cable

Based on:

- a. Application requirements
 - Maintain temperature
 - Maximum exposure temperature
- b. Watt density requirements
 - Power output at maintain temperature
- c. Electrical design
 - Available voltage
 - Circuit breaker capacity
 - Cold start impact
- d. Approval requirements
 - Hazardous area approval — Code requirements

Step 4: Determine Heat Tracing Circuit Lengths

Based on cable selection, electrical design and pipe lengths with allowances for;

- Valves, pumps, supports, other equipment
- Circuit fabrication and splice kits

Step 5: Choose Options/Accessories

Minimum installation accessories include:

- a. Power connection and end termination kits
- b. Cable attachment tape

Optional accessories include:

- Thermostatic control and monitoring

BASIS FOR A GOOD DESIGN

To become familiar with the requirements of a properly designed electric heat tracing system, use the five design steps detailed here and on the following pages. Once comfortable with the steps and the information required, use the design worksheet included at the end of this design guide for applying these steps to a complex piping application.

Step 1: Establish Design Parameters

Collect information relative to the following design parameters:

APPLICATION INFORMATION

- Pipe sizes or tubing diameters
- Pipe lengths
- Pipe material (metallic or nonmetallic)
- Type and number of valves, pumps or other equipment
- Type and number of pipe supports

Expected Minimum Ambient Temperature Generally, this number is obtained from weather data compiled for an area and is based on recorded historical data. There are times, however, when the minimum ambient will not be the outside air temperature. Examples include pipes and equipment located underground or inside buildings.

Minimum Start-Up Temperature This temperature differs from the minimum expected ambient in that the heating cable will typically be energized at a higher ambient temperature. This temperature will have an effect on the maximum circuit length and circuit breaker sizing for a given application (see Circuit Length Tables on pages 7-10).

Insulation Material and Thickness The selection charts in this design guide are based on fiberglass insulation with thicknesses shown in Tables 2.2 through 2.7. If insulation materials other than fiberglass are used, refer to the insulation correction factors shown in Table 2.1 or contact Thermon or a Thermon factory representative for design assistance.

Supply Voltage Thermon self-regulating cables are designed in two voltage groups: 110-130 Vac and 208-277 Vac. Determine what voltage(s) are available at a facility for use with heat tracing.

Note

1. All information in this design guide is based on metallic piping. For nonmetallic applications, contact Thermon.

BSX AND RSX 15-2 SELF-REGULATING CABLES

The power outputs shown in Table 3.2 and Graph 3.1 apply to cable installed on insulated metallic pipe at 120 and 240 Vac. When the heating cable will be operated on voltages other than 120 and 240, use Table 3.3 for 120 Vac nominal cable and Table 3.4 for 240 Vac nominal cable.

Table 3.2 BSX and RSX 15-2 Power Outputs at 120 & 240 Vac

Catalog Number 120 Vac Nominal	Catalog Number 240 Vac Nominal	Power Output at 50°F (10°C) W/ft (m)
BSX 3-1	BSX 3-2	3 (10)
BSX 5-1	BSX 5-2	5 (16)
BSX 8-1	BSX 8-2	8 (26)
BSX 10-1	BSX 10-2	10 (33)
-	RSX 15-2	15 (49)

Graph 3.1 BSX and RSX 15-2 Power Output Curves at 120 & 240 Vac




Table 3.3 BSX Power Output Multipliers (110-130 Vac)

Catalog Number	Operating Voltage (Vac)			
	110	115	120	130
BSX 3-1	0.90	0.93	1.0	1.07
BSX 5-1	0.92	0.96	1.0	1.08
BSX 8-1	0.91	0.96	1.0	1.08
BSX 10-1	0.92	0.96	1.0	1.08

Table 3.4 BSX and RSX 15-2 Power Output Multipliers (208-277 Vac)

Catalog Number	Operating Voltage (Vac)			
	208	220	240	277
BSX 3-2	0.87	0.90	1.0	1.13
BSX 5-2	0.88	0.92	1.0	1.12
BSX 8-2	0.89	0.93	1.0	1.12
BSX 10-2	0.89	0.93	1.0	1.12
RSX 15-2	0.89	0.93	1.0	1.12

CIRCUIT BREAKER SIZING

Maximum circuit lengths for various circuit breaker amperages are shown in Tables 3.5 and 3.6. Breaker sizing should be based on the National Electrical Code, Canadian Electrical Code or any other local or applicable code.

The circuit lengths shown are for nominal voltages of 120 and 240 Vac. While the power outputs will change based on the applied voltage, the circuit lengths will not significantly change; however, for detailed circuit information use CompuTrace.

Table 3.5 BSX Circuit Length vs. Breaker Size (120 Vac)

Catalog Number	120 Vac Service Voltage Start-Up Temperature °F (°C)	Max. Circuit Length vs. Breaker Size ft (m)		
		20A	30A	40A
BSX 3-1	50 (10)	360 (110)	360 (110)	360 (110)
	0 (-18)	325 (99)	360 (110)	360 (110)
	-20 (-29)	285 (87)	360 (110)	360 (110)
	-40 (-40)	260 (79)	360 (110)	360 (110)
BSX 5-1	50 (10)	240 (73)	300 (91)	300 (91)
	0 (-18)	205 (62)	300 (91)	300 (91)
	-20 (-29)	185 (56)	275 (84)	295 (90)
	-40 (-40)	165 (50)	250 (76)	265 (81)
BSX 8-1	50 (10)	190 (58)	240 (73)	240 (73)
	0 (-18)	150 (46)	225 (69)	240 (73)
	-20 (-29)	135 (41)	200 (61)	240 (73)
	-40 (-40)	120 (37)	180 (55)	215 (66)
BSX 10-1	50 (10)	160 (49)	200 (61)	200 (61)
	0 (-18)	110 (34)	170 (52)	200 (61)
	-20 (-29)	100 (30)	150 (46)	200 (61)
	-40 (-40)	90 (27)	135 (41)	180 (55)

Table 3.6 BSX & RSX 15-2 Circuit Length vs. Breaker Size (240 Vac)

Catalog Number	240 Vac Service Voltage Start-Up Temperature °F (°C)	Max. Circuit Length vs. Breaker Size ft (m)		
		20A	30A	40A
BSX 3-2	50 (10)	725 (221)	725 (221)	725 (221)
	0 (-18)	650 (198)	725 (221)	725 (221)
	-20 (-29)	575 (175)	725 (221)	725 (221)
	-40 (-40)	515 (157)	725 (221)	725 (221)
BSX 5-2	50 (10)	480 (146)	600 (183)	600 (183)
	0 (-18)	395 (120)	590 (180)	600 (183)
	-20 (-29)	350 (107)	525 (160)	590 (180)
	-40 (-40)	315 (96)	475 (145)	530 (162)
BSX 8-2	50 (10)	385 (117)	480 (146)	480 (146)
	0 (-18)	285 (87)	425 (130)	480 (146)
	-20 (-29)	255 (78)	380 (122)	480 (146)
	-40 (-40)	230 (70)	345 (116)	430 (131)
BSX 10-2	50 (10)	280 (85)	400 (122)	400 (122)
	0 (-18)	225 (69)	340 (104)	400 (122)
	-20 (-29)	200 (61)	300 (91)	400 (122)
	-40 (-40)	180 (55)	275 (84)	365 (111)
RSX 15-2	50 (10)	205 (63)	320 (98)	380 (116)
	0 (-18)	145 (45)	225 (70)	315 (97)
	-20 (-29)	130 (40)	200 (62)	280 (86)
	-40 (-40)	120 (36)	180 (55)	250 (77)

From: [Jeremy Wilson](#)
To: [Christopher Erb](#)
Cc: [Adam Neiwert](#)
Subject: RE: RFI #092-2 - Heat Trace Circuits (18017 -NVWWTP Douglas County)
Date: Tuesday, March 10, 2020 4:59:19 PM

Chris,

We have confirmation from Jacobs. BCP-151 is OK as is.

I am alright with the follow up RFI to document.

Thank you,

JEREMY WILSON, PE

Keller Associates, Inc.
DIRECT 775-451-7288 | CELL 970-556-4880

From: cerb@resourcedevelopmentco.com <cerb@resourcedevelopmentco.com>
Sent: Tuesday, March 10, 2020 7:24 AM
To: [Jeremy Wilson <jwilson@kellerassociates.com>](mailto:jwilson@kellerassociates.com)
Subject: RE: RFI #092-2 - Heat Trace Circuits (18017 -NVWWTP Douglas County)

Jeremy

Please see Jim's question below.

Do we need to upsize the Panel BCP_151 as well?

Let me know how you want to respond to this question (RFI #092-3/Email confirmation)?

Thanks
Chris Erb
RDC

From: [Jim Andrews <jim@creekside-electric.com>](mailto:jim@creekside-electric.com)
Sent: Monday, March 9, 2020 9:58 AM
To: cerb@resourcedevelopmentco.com
Cc: 'Brandon Beckman' <BBECKMAN@RESOURCEDEVELOPMENTCO.COM>; anevarez@resourcedevelopmentco.com
Subject: RE: RFI #092-2 - Heat Trace Circuits (18017 -NVWWTP Douglas County)

Chris,

The engineer has upsized feeder breaker, transformer and BCP-150 main circuit breaker, but did not

upsized panel BCP-151 where all the added circuits are being supplied. It is still being fed by a 60A circuit breaker from BCP-150.

Can you check on this and make sure he didn't miss upsizing this panel?

Jim Andrews

Estimator/PM

Creekside Electrical Contractors, Inc.

3059 Airport Rd. Carson City, NV 89706

775-841-5558 (o)

775-841-5565 (f)

775-220-3664 (c)

From: cerb@resourcedevelopmentco.com [mailto:cerb@resourcedevelopmentco.com]

Sent: Friday, February 28, 2020 9:24 AM

To: 'Jim Andrews'

Cc: 'Brandon Beckman'; anevarez@resourcedevelopmentco.com

Subject: RFI #092-2 - Heat Trace Circuits (18017 -NWWTP Douglas County)

Jim

Please provide a PCO for your portion of the work related to RFI #092-2 Heat Trace Circuits (See Attached).

Thanks

Chris Erb

RDC

775-842-0232



Work Change Directive

Owner:	Douglas County	WCD No.:	34
Project Name:	NVWWTP Improvements Project	Project No.:	216030
Contractor:	Resource Development Company	Issued By:	Jeremy Wilson
Attention:	Alex Nevarez	Date Issued:	10/05/2020

Reason for Change: This WCD covers the labor, materials, equipment, and installation cost to cut and cap the abandoned effluent piping.

Description of change(s): The old effluent pumps have been removed from the operations building. Subsequently the discharge piping was abandoned. However, the discharge piping connects to a live pipeline in a nearby vault after a check valve. Unfortunately, the check valve is no longer functioning which is causing water to flow back into the abandoned pipe. To prevent this, the abandoned pipe will be cut and capped outside of the vault described above and in the picture attached.

It is the engineer’s understanding that the upstream section of pipe is completely abandoned with no planned future uses.

Attachments: Contractor’s proposed change order and photos.

Contract Sum Adjustment: The proposed basis of adjustment to the Contract Sum or Guaranteed Maximum Price is (Place an X in the appropriate box).

- Lump Sum increase of \$3,418.53
- Unit Price of
- Cost of Work not to exceed
- Contractor Submit TM Ticket

Contract Time Adjustment: A contract time extension of 1 day is anticipated as part of this WCD.

When signed by the Owner and Engineer authorized representatives and received by the Contractor, this document becomes effective immediately as a Construction Change Directive, and the Contractor shall proceed with the change(s) described above. The Contactor's signature, signed by an authorized representative, indicates agreement with the proposed adjustments in Contract Sum and Contract Time set forth in this Construction Change Directive.


Keller Associates, Inc.

Engineer

1325 Airmotive Way Suite 380

Reno, Nevada 89502

(Address)



By (Authorized Signature)

Jeremy Wilson

(Printed Name)

10/05/2020

Date

Douglas County

Owner

1120 Airport Road, Bldg F2

Minden, Nevada 89423

(Address)



By (Authorized Signature)

Philip Ritger

(Printed Name)

10-07-2020

Date


Resource Development Company

Contractor

1050 Linda Way

Sparks, Nevada 89431

(Address)




By (Authorized Signature)

Christopher Erb

(Printed Name)

10/09/20

Date



ch2m

CIVIL

SITE PLAN


DESIGN OFFICE
2323 AIRPARK DRIVE
REDDING, CA 96001
(530) 243-8331

NORTH VALLEY WWTPT
IMPROVEMENTS PROJECT
DOUGLAS COUNTY PUBLIC WORKS (DCWP)
DOUGLAS COUNTY, NV

NO.	DATE	DR	CHK	APVD	BY	APVD
1		T HOWARD	K POPE	LALLIGER	J DEHN	

6-22-18

DATE	JUNE 2018
PROJ	592-C-2002
DRAWN	30 OF 111
CHECKED	
PROJECT	
PROJECT NUMBER	
SCALE	
DATE	
PROJECT	
DRAWN	
CHECKED	
PROJECT	





Pipe to be cut and capped



RESOURCE DEVELOPMENT COMPANY

PCO #61 – EFFLUENT PIPE CAP

Date: SEPTEMBER 24, 2020 REVISED OCTOBER 1, 2020

Project: NVWWTP Improvements

ATTN: Jeremy Wilson, PE – Keller Associates

Mr. Wilson,

This PCO is to document the process for RDC to excavate around, cut, and cap the existing effluent pipe to be abandoned. RDC will also fill, cut, and cap the pipe inside the lab building.

PCO #61 Extra Work Total: \$3,418.53

Additional Contract Days: 1 Contract Days

Please don't hesitate to contact me if you have any questions or need any clarification.

Sincerely,

Christopher Erb

Christopher Erb

Resource Development Company

Cc: Ron Roman, PE – DCPW

 Scott McCullough - DCPW



RESOURCE DEVELOPMENT COMPANY

DATE 9/24/2020

PCO #61 - IEFFLUENT PIPE CAP
NVWWTP - DOUGLAS COUNTY
RDC PROJECT # 18017

EQUIPMENT			
	HOURLY RATE	HOURS	SUBTOTAL
Backhoe 310 SE	39.60	8.00	316.80
Work Truck	32.48	8.00	259.84

LABOR			
	HOURLY RATE	HOURS	SUBTOTAL
Superintendent	120.00	4.50	540.00
Project Manager	120.00	1.00	120.00
Operator - B/T/E	77.36	8.00	618.88
Laborer	47.54	16.00	760.64

MATERIAL			
	MATERIAL COST	TAX	SUBTOTAL
CONCRETE	172.00	12.21	184.21
CAPS	80.00	5.68	85.68
	0.00	0.00	0.00

TOTALS				
	SUBTOTAL	MARK-UP %	MARK-UP	TOTAL
Equipment	576.64	15%	86.50	\$ 663.14
Labor	2039.52	15%	305.93	\$ 2,345.45
Material	269.89	15%	40.48	\$ 310.38
Bonds & Insurance (3%)	3318.96	3%	99.57	\$ 99.57

INCREASE IN CONTRACT TIME 1 DAYS

JOB TOTAL 3,418.53

Submitted By: Christopher Erb

Douglas County State of Nevada

CERTIFIED COPY

I certify that the document to which this certificate is attached is a full and correct copy of the original record on file in the Clerk-Treasurer's Office on this

13th day of September 2020
By [Signature] Deputy